



**energysMART**  
Your Efficiency Solutions

## EnergySmart Residential Standalone Rebates

For Homeowners and Ownerships Up To 4 Units

Receive 25% of project cost up to \$300	
"Cold Climate" Rated ENERGY STAR <u>Ducted</u> Air Source Heat Pump <sup>1</sup>	HSPF $\geq 9.0$ /SEER $\geq 15.0$ /COP $\geq 1.75@5^{\circ}\text{F}$ or capacity @ 5°F of at least 70% of BTU @ 47°F . Must be NEEP.org certified. <i>Maximum rebate amount per home</i>
"Cold Climate" Rated ENERGY STAR <u>Ductless</u> (Mini-Split) Air Source Heat Pump <sup>1</sup>	HSPF $\geq 10.0$ /SEER $\geq 15.0$ /COP $\geq 1.75@5^{\circ}\text{F}$ or capacity @ 5°F of at least 70% of BTU @ 47°F . Must be NEEP.org certified. <i>Maximum rebate amount per home</i>
Ground Source Heat Pump	5.5 tons or smaller, 14.1 EER. Must be ENERGY STAR certified
Receive 25% of project cost up to \$200	
Solar PV	Includes roof, ground mounted system or a Community Solar Garden subscription ( <i>must purchase capacity to meet at least meet 50% of existing household electricity consumption</i> ) Installation by NABCEP certified installer only
Receive 25% of project cost up to \$100	
"Non-Cold" Climate Rated ENERGY STAR <u>Ducted</u> Air Source Heat Pump <sup>1</sup>	HSPF $\geq 8.5$ /SEER $\geq 15.0$ <i>Maximum rebate amount per home</i>
"Non-Cold" Climate Rated ENERGY STAR <u>Ductless</u> Air Source Heat Pump <sup>1</sup>	HSPF $\geq 8.5$ /SEER $\geq 15.0$ <i>Maximum rebate amount per home</i>
Attic Insulation with Air Sealing	R-49 minimum required in open attic; cathedral ceilings will vary with rafter depth but must meet requirements of 2012 IECC. Must perform air sealing in attics prior to adding insulation.*

**Receive 25% of project cost up to \$100 (*cont.*)**

Wall Insulation	R-19 minimum; fill wall cavity where R-19 is not possible. For solid walls such as brick or concrete, exterior rigid insulation must be added to a level of $\geq$ R-10.
Foundation (Basement or Crawl Space) Insulation and Air Sealing	Crawlspace as outlined in the 2012 IECC. R-15 continuous or R-19 cavity insulation with a vapor-permeable air barrier over insulation. Crawlspaces must have sealed vapor barrier over dirt crawl space floor and ventilation, per 2012 IECC.
ENERGY STAR Electric Heat Pump Water Heater	Must be Energy Star certified with a minimum Energy Factor of 2.0

***Marshall Fire \$100 bonus rebate for the removal of smoke damaged insulation***

Attic, Wall, Basement and Crawlspace Insulation Removal	For homes affected by smoke and particulates from the Marshall fire an additional \$100 per measure will be added to the insulation rebate(s) to help cover the necessary removal of existing smoke contaminated insulation. Submission of contractor invoice required noting the removal of contaminated insulation and where missing, air sealing (inc. attic top plates*).
---	---

## Conditions

- Rebates are only available to **EnergySmart participants** and for the measures listed. Engagement in EnergySmart and pre-project qualification must occur **before** purchasing an eligible appliance or completing the energy efficiency project for which a rebate is being applied for.
- **Rebate funds are limited, are subject to change, and will be awarded on a first-come, first-served basis.**
- The rebate award will be based on the levels published at the time that an invoice for work completed has been submitted to EnergySmart.
- All work must be completed and invoiced between **April 1, 2022 and June 30, 2022** to qualify for these rebates.
- Total lifetime **maximum** of all **EnergySmart** rebates cannot exceed **\$1,800/home** and **\$6,000/owner** of multiple properties (inc past and present EnergySmart rebates). Exception allowed if due to the Solar PV bonus.
- Multi-Family Units of 5 or more are not eligible for this rebate.
- Rebates cannot exceed the cost of the measure after all other rebates are applied.
- All upgrades must be for or directly benefit unit occupants. (e.g. Only upper units can receive an attic insulation rebate when applying for multiple unit rebates.
- All work must meet all applicable building or energy codes, and all required permits must be obtained. Combustion Appliance Zone (CAZ) testing must occur as a health/safety measure before and after the upgrade depending on the type of upgrade. *Please feel free to speak with your Advisor about the importance of CAZ testing.*
- ! For air source heat pump (ASHPs) a thermostatic expansion valve within the appliance is required. Must be used for both heating and cooling purposes.
- \* Air sealing requirements include the sealing of the void directly above all accessible exterior top plates in attic space.